

2018-07-20

5011667308-SL13

DVP-SLIM

Instruction Sheet

安 裝 說 明

安 裝 說 明

Digital I/O Extension Unit

數位I/O擴充機

数字I/O扩展机



Warning

ENGLISH

EN ✂ DVP-SLIM is an OPEN-TYPE device. It should be installed in a control cabinet free of airborne dust, humidity, electric shock and vibration. To prevent non-maintenance staff from operating DVP-SLIM, or to prevent an accident from damaging DVP-SLIM, the control cabinet in which DVP-SLIM is installed should be equipped with a safeguard. For example, the control cabinet in which DVP-SLIM is installed can be unlocked with a special tool or key.

EN ✂ DO NOT connect AC power to any of I/O terminals, otherwise serious damage may occur. Please check all wiring again before DVP-SLIM is powered up. After DVP-SLIM is disconnected, Do NOT touch any terminals in a minute. Make sure that the ground terminal ④ on DVP-SLIM is correctly grounded in order to prevent electromagnetic interference.


FR ✂ DVP-SLIM est un module OUVERT. Il doit être installé que dans une enceinte protectrice (boîtier, armoire, etc.) saine, dépourvue de poussière, d'humidité, de vibrations et hors d'atteinte des chocs électriques. La protection doit éviter que les personnes non habilitées à la maintenance puissent accéder à l'appareil (par exemple, une clé ou un outil doivent être nécessaire pour ouvrir a protection).

FR ✂ Ne pas appliquer la tension secteur sur les bornes d'entrées/Sorties, ou l'appareil DVP-SLIM pourra être endommagé. Merci de vérifier encore une fois le câblage avant la mise sous tension du DVP-SLIM. Lors de la déconnection de l'appareil, ne pas toucher les connecteurs dans la minute suivante. Vérifier que la terre est bien reliée au connecteur de terre ④ afin d'éviter toute interférence électromagnétique.

Introduction

Thank you for choosing Delta DVP-Slim series programmable logic controller. DVP-Slim digital I/O extension unit offers 6 ~ 16 points, and the maximum digital I/O extension points (including the MPU) can reach 256 points. In addition, maximum 8 additional special modules (AD/DA/PT/TC/XA/PU) can be extended to DVP-Slim series extension unit.

Product Profile & Outline



Model Information

Model name	Power supply	Input		Output		Dimension (mm)			Outline	
		Points	Type	Points	Type					
DVP08SP11R	24VDC	4	DC Type Sink/Source	4	Relay	25.2	90	60		
DVP16SP11R		8		8						
DVP08SP11T		4		4	Transistor (Sink)					
DVP16SP11T		8		8						
DVP08SP11TS		4		4	Transistor (Source)					
DVP16SP11TS		8		8						
DVP08SM10N		8	100 ~ 120VAC	0	N/A					

Model name	Power supply	Input		Output		Dimension (mm)	Outline
		Points	Type	Points	Type		
DVP08SM11N		8	DC Type	0			
DVP16SM11N		16	Sink/Source	0			
DVP06SN11R		0		6	Relay		
DVP08SN11R		0		8			
DVP08SN11T		0	N/A	8	Transistor (Sink)		
DVP16SN11T		0		16			
DVP08SN11TS		0		8	Transistor (Source)		
DVP16SN11TS		0		16			

Specifications

Electrical Specifications


Item	Model	08SM11N 08SM10N	16SM11N	08SN11R/T /TS	08SP11R/T /TS	16SP11R/T	16SP11TS	06SN11R	16SN11T /TS
Power supply voltage		24VDC (-15%~20%) (with DC input polarity reverse protection)							
Motion specification		Within 5ms of the momentary power loss, the device will keep on operating							
Power consumption		1W	2W	1.5W	1.5W	2W	2W	1.5W	1W
Insulation resistance		> 5MΩ (all I/O point-to-ground: 500VDC)							
Noise immunity		ESD (IEC 61131-2, IEC 61000-4-2): 8KV Air Discharge EFT (IEC 61131-2, IEC 61000-4-4): Power Line: 2KV, Digital I/O: 1KV, Analog & Communication I/O: 1KV Damped-Oscillatory Wave: Power Line: 1KV, Digital I/O: 1KV RS (IEC 61131-2, IEC 61000-4-3): 26MHz ~ 1GHz, 10V/m							
Earth		The diameter of grounding wire shall not be less than that of L, N terminal of the power. When many PLCs are in use at the same time, please make sure every PLC is properly grounded.							
Operation / storage environment		Operation: 0°C ~ 55°C (temperature), 5% ~ 95% (humidity), pollution degree 2 Storage: -25°C ~ 70°C (temperature), 5% ~ 95% (humidity)							
Shock / vibration immunity		International standards: IEC61131-2, IEC 68-2-6 (TEST Fc) / IEC61131-2 & IEC 68-2-27 (TEST Ea)							
Weight (g)		162 / 141	146	154 / 146	141 / 136	162 / 154	151	200	70

I/O Point Specifications

Input Point		
Input point type	DC	AC
Input type	DC Type (Sink or Source)	-
Input resistance	-	19Kohm/50Hz 16Kohm/60Hz
Input current/voltage	24VDC 5mA	85 ~ 132VAC, 50 ~ 60Hz 9.2mA, 110VAC/60Hz
Active level	Off → On: more than 16.5VDC	More than 79VAC
	On → Off: less than 8VDC	Less than 30VAC
Response time	Approx. 10ms	Off → On < 15ms On → Off < 20ms
Circuit isolation / operation instruction	By photocoupler / LED On	

Output Point				
Output type	Relay-R	Relay-R (*1)	Transistor-T (Sink)	Transistor-T (Source)
Current specification	1.5A/1 point (5A/COM)	6A/1 point	55°C 0.1A/1 point 50°C 0.15A/1 point 45°C 0.2A/1 point 40°C 0.3A/1 point (2A/COM)	55°C 0.3A/1 point (2A/COM)
Voltage specification	< 250VAC, 30VDC	< 250VAC, 30VDC	30VDC	30VDC
Maximum load	*2	*3	9W	9W
Response time	Approx. 10ms	Approx. 10ms	Off → On 15us On → Off 25us	Off → On 15us On → Off 25us

*1: Only applicable in DVP06SN11R.



Installation & Wiring


Terminals of DVP-Slim

08SM11N	08SM10N	16SM11N	06SN11R	08SN11R 08SN11T	16SN11T	08SN11TS	16SN11TS


08SP11R 08SP11T	16SP11R	08SP11TS	16SP11TS

Connection

Step 1 Screw open the side cover of the extension unit, and you will see the connection port.



[Figure 3]




[Figure 5]

Installation & Wiring

Install the PLC in an enclosure with sufficient space around it to allow heat dissipation (as shown in the figure below).

How to install DIN rail

DVP-PLC can be secured to a cabinet by using the DIN rail of 35mm in height and 7.5mm in depth. When mounting PLC to the DIN rail, be sure to use the end bracket to stop any side-to-side movement of the PLC and reduce the chance of wires being loosen. A small retaining clip is at the bottom of the PLC. To secure PLC to the DIN rail, place the clip onto the rail and gently push it up. To remove it, pull the retaining clip down and gently remove the PLC from the DIN rail.



Notes

- DO NOT install PLC in an environment with
 - Dust, smoke, metallic debris, corrosive or flammable gas
 - High temperature, humidity
 - Direct shock and vibration

During the engineering

- DO NOT drop tiny metallic conductor into the PLC when screwing and wiring.
- There should be a margin of more than 50mm between the PLC and other control devices, and the PLC should be placed away from high voltage wire and power equipment.

Arrangement of I/O Points

No matter the MPU with how many points you are using, the input point No. of the first connected extension unit has to start from X20 and output point No. from Y20. The MPU is able to connect to maximum 14 digital extension units. The connection of MPU and extension units is demonstrated in the figure below.


PLC	Model	Input points	Output points	Input point No.	Output point No.
MPU	SS/SA/SX/SC	8	4/6	X0 ~ X7, X10, X11	Y0 ~ Y5, X10, X11
EXT1	16SP11T	8	8	X20 ~ X27	Y20 ~ Y27
EXT2	08SM11N	8	0	X30 ~ X37	-
EXT3	06SN11R	0	6	-	Y30 ~ Y35
EXT4	08SP11R	4	4	X40 ~ X43	Y40 ~ Y43

The 3rd extension module 06SN11R will be regarded as 8-point output. The 2 output points of bigger No. will have no actual corresponding output points.

The 4th extension module 08SP11R will be regarded as 8-point input/8-point output. The 4 input points and 4 output points of bigger No. will have no actual corresponding input/output points. Therefore, it is suggested that they placed in the end of the series connection to make the No. of I/I points continuous.

Input Point Wiring & Specification


There are two types of signals at input points, DC and AC, and there are two types of DC inputs, Sink and Source. The wiring is as follows.



AC Wiring:

Wiring Loop		110VAC Input Specification	
	Input voltage	85 ~ 132VAC, 50 ~ 60Hz	
	Input resistance	19Kohm/50Hz, 16Kohm/60Hz	
	Input current	9.2mA 110VAC/60Hz	
	On/Off voltage level	79V 3.8mA/30V 2.5mA	
	Response time	15ms	
Circuit isolation/operation instruction		By photocoupler / LED On	


Relay Output Wiring Circuit (Sink):



- DO NOT wire empty terminal
- Fuse
- Reverse current protection diode*1
- Manual exclusive output*2
- Emergency stop: by external switch
- Surge absorber*3
- Inductive load
- Incandescent light (resistive load)
- DC power supply
- AC power supply

- *1: There is no internal protection circuit in the output relay of the PLC; therefore when activating an inductive load, we suggest you parallelly connect a reverse current protection diode to extend the life of the contact.
 - The diode has to be able to endure max. 5 ~ 10 times of load voltage.
 - The positive current of the diode has to be bigger than load current.
- *2: Manual exclusive output uses external circuit and forms an interlock, together with the PLC internal program, to ensure safety protection in case of any unexpected errors.
- *3: There is no internal protection circuit in the output relay of the PLC; therefore when activating an inductive load, we suggest you parallelly connect a surge absorber (0.1uF + *100ohm to 120ohm) to reduce the noise on AC load and extend the life of the contact.


Transistor Output Wiring Circuit (Sink):



- DO NOT wire empty terminal
- Emergency stop
- Fuse
- Manual exclusive output*1
- DC power supply
- Incandescent light (resistive load)
- Reverse current protection diode*2
- Inductive load
- Resistive load
- Y1, Y3 (refer to other wiring methods)

- *1: Manual exclusive output uses external circuit and forms an interlock, together with the PLC internal program, to ensure safety protection in case of any unexpected errors.
- *2: Use a zener diode (39V) in the PLC to protect the transistor output. When activating inductive load, we suggest you parallelly connect a reverse current protection diode.

Transistor Output Wiring Loop (Source):



- Y6, Y7 (refer to other wiring methods)
- Emergency stop
- Fuse
- Manual exclusive output*1
- DC power supply
- Incandescent light (resistive load)
- Reverse current protection diode*2
- Inductive load
- Resistive load

- *1: Manual exclusive output uses external circuit and forms an interlock, together with the PLC internal program, to ensure safety protection in case of any unexpected errors.
- *2: Use a zener diode (39V) in the PLC to protect the transistor output. When activating inductive load, we suggest you parallelly connect a reverse current protection diode.

注意事項


繁體中文

- 請在使用之前，詳細閱讀本使用說明書。
- 本機為開放型 (OPEN TYPE) 機殼，因此使用者使用本機時，必須將之安裝於具防塵、防潮及免於電擊／衝擊意外之外殼設備內。另必須具備保護措施（如：特殊之工具或鑰匙才可打開）防止非維護人員操作或意外衝擊本機，造成危險及損壞。
- 交流輸入電源不可連接於直流類型之輸入／輸出端，否則可能造成嚴重的損壞，因此請在上電之前再次確認電源配線。請在上電時觸碰任何端子。


產品簡介

謝謝您採用台灣 DVP-SLIM 系列可程式控制器。DVP-SLIM 系列 6 ~ 16 點擴充，含主機最大數位輸入／輸出擴充分別可達 256 點。另備特殊模組 (AD/DA/PT/TC/XA/PU) 擴充功能，最多可擴充 8 台特殊模組。

產品外觀及各部介紹



機種型號

機種	電源	輸入單元		輸出單元		尺寸 (mm)			外形參考	
		點數	形式	點數	形 式					
DVP08SP11R	24VDC	4	DC Type Sink/Source	4	繼電器	25.2	90	60		
DVP16SP11R		8		8						
DVP08SP11T		4		4	電晶體(Sink)					
DVP16SP11T		8		8						
DVP08SP11TS		4	DC Type Sink/Source	4	電晶體(Source)					
DVP16SP11TS		8		8						
DVP08SM10N		8		100 ~ 120VAC	0					無
DVP08SM11N		8		DC Type Sink/Source	0					
DVP16SM11N		16		0						
DVP06SN11R		0	無	6	繼電器					
DVP08SN11R		0		8						
DVP08SN11T		0		8	電晶體(Sink)					
DVP16SN11T		0		16						
DVP08SN11TS		0		8	電晶體(Source)					

機種	電源	輸入單元		輸出單元		尺寸 (mm)			外形參考
		點數	形 式	點數	形 式				
DVP16SN11TS		0		16					

功能規格

電氣規格

項目\機種	08SM11N 08SM10N	16SM11N	08SN11R/T /TS	08SP11R/T /TS	16SP11R/T	16SP11TS	06SN11R	16SN11T /TS
電源電壓	24VDC (-15%～20%) (具直流輸入電源極性反接保護)							
動作規格	電源瞬間斷電 5ms 以內繼續運轉							
消耗電力	1W	2W	1.5W	1.5W	2W	2W	1.5W	1W
絕緣阻抗	5 MΩ 以上（所有輸出／入點對地之間 500VDC）							
雜訊免疫力	ESD (IEC 61131-2, IEC 61000-4-2): 8KV Air Discharge EFT (IEC 61131-2, IEC 61000-4-4): Power Line: 2KV, Digital I/O: 1KV, Analog & Communication I/O: 1KV Damped-Oscillatory Wave: Power Line: 1KV, Digital I/O: 1KV RS (IEC 61131-2, IEC 61000-4-3): 26MHz～1GHz, 10V/m							
接地	接地配線之線徑不得小於電源端 L、N 之線徑（多台 PLC 同時使用時，請務必單點接地）							
操作／儲存環境	操作：0℃～55℃（溫度），5%～95%（濕度），污染等級 2 儲存：-25℃～70℃（溫度），6%～95%（濕度）							
耐振動／衝擊	國際標準規範 IEC61131-2, IEC 68-2-6 (TEST Fc)/ IEC61131-2 & IEC 68-2-27 (TEST Ea)							
重量（約）(g)	162 / 141	146	154 / 146	141 / 136	162 / 154	151	200	70

輸入點規格

輸入點電氣規格		
輸入點形式	直 流	交 流
輸入形式	直 流 (Sink 或 Source)	-
輸入阻抗	-	19Kohm/50Hz 16Kohm/60Hz
輸入電壓電流	24VDC 5mA	85~132VAC 50~60Hz 9.2mA 110VAC/60Hz
動作位準	Off → On : 16.5VDC 以上	79VAC 以上
	On → Off : 8VDC 以下	30VAC 以下
反應時間	約 10ms	Off → On < 15ms On → Off < 20ms
電路隔離／操作指示	光耦合器 / LED On	

輸出點電氣規格			
輸出點形式	繼電器-R	繼電器-R (*1)	電晶體-T (Sink) 電晶體-T (Source)
電流規格	1.5A/1 點 (5A/COM)	6A/1 point	55℃ 0.1A/1 點、 50℃ 0.15A/1 點、 45℃ 0.2A/1 點、 40℃ 0.3A/1 點 (2A/COM)
電壓規格	250VAC, 30VDC 以下	250VAC, 30VDC 以下	30VDC
最大負載	*2	*3	9W
反應時間	約 10ms	約 10ms	Off → On 15us On → Off 25us

- *1: 僅適用於 06SN11R 機種
- *2: 請參閱英文版[Figure 1]
- *3: 請參閱英文版[Figure 2]

安裝及配線

數位 I/O 擴充機之端子配置圖

請參考英文版之端子配置圖。

系統組合

步驟 1 利用螺絲起子將擴充側蓋打開，會出現擴充機連接接口。（請參閱英文版[Figure 3]）



步驟 2 再利用螺絲起子將擴充機固定扣往上撥。（請參閱英文版[Figure 4]）

步驟 3 調整好主機和擴充機的定位孔，並且將主機的擴充機連接接口與擴充機接合，此時主機與擴充機之間緊密結合。（請參閱英文版[Figure 5]）

步驟 4 將擴充機固定扣往下扣住，完成與主機之系統組合。（請參閱英文版[Figure 6]）

DVP 盤內安裝及配線

DVP 系列 PLC 在安裝時，請裝配於封閉式之控制箱內，其周圍應保持一定之空間（如下圖所示），以確保 PLC 散熱功能正常。



注意事項

- 請勿將 PLC 裝置於
- 落塵大、油煙、金屬性粉塵及腐蝕性或可燃性氣體的環境
 - 高溫、結露的環境
 - 有直接振動及衝擊的場所

- 施工注意**
- 鎖螺絲及配線時請避免微小的金屬碎屑掉入 PLC 內部。
 - PLC 與其它之控制元件應保持 50mm 以上之間隔，並應遠離高壓線及動力設備。

輸出入點序號排列

無論使用任何點數的主機連接擴充機，所連接的第一台擴充機，輸入點編號由 X20 依序排列，輸出點編號亦由 Y20 開始依序排列，主機連接數位擴充機最多可連接 14 台，若使用者所連接的系統如下：

系統組合範例：

PLC	機種	輸入點數	輸出點數	輸入點編號	輸出點編號
MPU	SS/SA/SX/SC	8	4/6	X0～X7, X10, X11	Y0～Y5, X10, X11
EXT1	16SP11T	8	8	X20～X27	Y20～Y27

EXT2	08SM11N	8	0	X30～X37	-
EXT3	06SN11R	0	6	-	Y30～Y35
EXT4	08SP11R	4	4	X40～X43	Y40～Y43

第 3 台擴充機 06SN11R 會被視為 8 點輸出，序號較高的 2 個輸出點則沒有對應實際的輸出點。

第 4 台擴充機 08SP11R 會被視為 8 點輸入/8 點輸出，序號較高的 4 個輸入點及 4 個輸出點則沒有對應實際的輸入/輸出點，因此建議置於串聯末端，輸入/出點編號才會連續。

輸入端配線及規格

輸入點之入力信號共有兩種：為直流電源 DC 輸入及交流電源 AC 輸入。

DC 型式共有兩種接法，SINK（請參閱英文版[Figure 7]）及 SOURCE（請參閱英文版[Figure 8]）。

AC 型式配線

配線回路	110VAC 輸入規格
	輸入電壓 85～132VAC, 50～60Hz 輸入阻抗 19Kohm/50Hz, 16Kohm/60Hz 輸入電流 9.2mA 110VAC/60Hz On/Off 電壓位準 79V 3.8mA/30V 2.5mA 反應時間 15ms 電路隔離／操作指示 光耦合器／LED On

實用的繼電器輸出回路配線（Sink）（詳細配線圖請參閱英文版 [Figure 9]）

- ❶ 空端子請勿配線

❷ 保險絲

❸ 緊急停止：使用外部開關
- ❶ 反向電流保護二極體：在 PLC 的輸出繼電器並沒有內部保護電路，因此若使用在直流電感性負載時，請並聯接上一個反向電流保護二極體，可增加接點壽命。反向電流保護二極體須符合下列規格：必須能承受最大 5～10 倍的負載電壓及正向電流須大於負載電流。

❷ 互斥輸出：利用外部電路形成互鎖，配合 PLC 內部程式，確保任何異常突發狀況發生時，均有安全的保護措施。

❸ 突波吸收器：在 PLC 的輸出繼電器並沒有內部保護電路，因此若使用在交流電感性負載時，請並聯接上一個突波吸收器（0.1uF + *100ohm to 120ohm*）可减少交流負載上的雜訊，可增加接點壽命。
- ❷ 電感性負載

❹ 白熾燈（電阻性負載）

❺ 直流電源供給

❻ 交流電源供給

實用的電晶體輸出回路配線（Sink）（詳細配線圖請參閱英文版 [Figure 10]及[Figure 11]）

- ❶ 空端子請勿配線

❷ 緊急停止

❸ 保險絲
- ❶ 互斥輸出：利用外部電路形成互鎖，配合 PLC 內部程式，確保任何異常突發狀況發生時，均有安全的保護措施。

❷ 直流電源供應

❹ 白熾燈（電阻性負載）
- ❷ 反向電流保護二極體：在 PLC 內部使用齊納二極體（39V）來保護電晶體輸出，若驅動電感性負載時，建議並聯接上一個反向電流保護二極體。

❸ 電感性負載

❺ 電阻性負載

Ⓜ Y1,Y3 可參考其它配線方式

實用的電晶體輸出迴路配線（Source）（詳細配線圖請參閱英文版 [Figure 12]）

- ❶ Y6,Y7 可參考其它配線方式

❷ 緊急停止

❸ 保險絲
- ❶ 互斥輸出：利用外部電路形成互鎖，配合 PLC 內部程式，確保任何異常突發狀況發生時，均有安全的保護措施。

❷ 直流電源供應

❹ 白熾燈（電阻性負載）
- ❷ 反向電流保護二極體：在 PLC 內部使用齊納二極體（39V）來保護電晶體輸出，若驅動電感性負載時，建議並聯接上一個反向電流保護二極體。

❸ 電感性負載

❺ 電阻性負載

⚠ 注意事项 简体中文

- ✓ 请在使用之前，详细阅读本使用说明书。
- ✓ 本机为开放型（OPEN TYPE）机壳，因此使用者使用本机时，必须将其安装于具防尘、防潮及免于电击／冲击意外的外壳配线箱内。另必须具备保护措施（如：特殊的工具或钥匙才可打开）防止非维护人员操作或意外冲击本体，造成危险及损坏。
- ✓ 交流输入电源不可连接于直流类型的输入／出信号端，否则可能造成严重的损坏，因此请在上电之前再次确认电源配线。请勿在上电时触摸任何端子。


产品简介

感谢您采用台达 DVP-SLIM 系列可编程控制器。DVP-SLIM 系列 6～16 点扩展，含主机最大数字输入／输出扩展分别可达 256 点。另备特殊模块(AD/DA/PT/TC/XA/PU) 扩展功能，最多可扩展 8 台特殊模块。

产品外观及各部介绍

	❶ 电源、低电压指示灯 ❷ 机种名称 ❸ 扩展机固定扣 ❹ 输出/入端子 ❺ DIN 轨固定扣	❻ 扩展机定位孔 ❼ 铭牌 ❽ 扩展机固定扣 ❾ DIN 轨槽 (35mm) ❿ 扩展机连接接口
--	--	---

机种型号

机种	电源	输入单元		输出单元		尺寸 mm			外形参考
		点数	形式	点数	形 式				
DVP08SP11R	24VDC	4	DC Type Sink/Source	4	继电器	25.2	90	60	
DVP16SP11R		8		8					
DVP08SP11T		4		4	晶体管 (Sink)				
DVP16SP11T		8		8					
DVP08SP11TS		4		4	晶体管(Source)				
DVP16SP11TS		8		8					
DVP08SM10N		8	100 ~ 120VAC	0	无				
DVP08SM11N		8	DC Type Sink/Source	0					
DVP16SM11N		16	0						
DVP06SN11R		0	无	6	继电器				
DVP08SN11R		0		8					
DVP08SN11T		0		8	晶体管(Sink)				
DVP16SN11T		0		16					
DVP08SN11TS		0		8	晶体管(Source)				
DVP16SN11TS		0		16					

功能规格

电气规格

机 种	08SM11N 08SM10N	16SM11N	08SN11R/T /TS	08SP11R/T /TS	16SP11R/T	16SP11TS	06SN11R	16SN11T /TS
电源电压	24VDC (-15%～20%)（具直流输入电源极性反接保护）							
动作规格	电源瞬间断电 5ms 以內继续运转							
消耗电力	1W	2W	1.5W	1.5W	2W	2W	1.5W	1W
绝缘阻抗	5 MΩ 以上（所有输出／入点对地之间 500VDC）							
噪声免疫力	ESD (IEC 61131-2, IEC 61000-4-2): 8KV Air Discharge EFT (IEC 61131-2, IEC 61000-4-4): Power Line: 2KV, Digital I/O: 1KV, Analog & Communication I/O: 1KV Damped-Oscillatory Wave: Power Line: 1KV, Digital I/O: 1KV RS (IEC 61131-2, IEC 61000-4-3): 26MHz～1GHz, 10V/m							
接地	接地配线的线径不得小于电源端 L、N 的线径（多台 PLC 同时使用时，请务必单点接地）							
操作／储存环境	操作：0℃～55℃（温度），5～95%（湿度），污染等级 2 储存：-25℃～70℃（温度），5～95%（湿度）							
耐振动／冲击	国际标准规范 IEC61131-2, IEC 68-2-6 (TEST Fc)/IEC61131-2 & IEC 68-2-27 (TEST Ea)							
重量(约): (g)	162 / 141	146	154 / 146	141 / 136	162 / 154	151	200	70

输入点规格

输入点电气规格				
输入点形式	直 流		交 流	
输入形式	直 流（SINK 或 SOURCE）		-	
输入阻抗	-		19Kohm/50Hz 16Kohm/60Hz	
输入电压/电流	24VDC 5mA		85~132VAC 50~60Hz 9.2mA 110VAC/60Hz	
动作位准	Off → On: 16.5VDC 以上		79VAC 以上	
	On → Off: 8VDC 以下		30VAC 以下	
反应时间	约 10ms		Off → On < 15ms On → Off < 20ms	
电路隔离 / 操作指示	光耦合器 / LED On			
输出点电气规格				
输出点形式	继电器-R	继电器-R (*1)	晶体管-T (Sink)	晶体管-T (Source)
电流规格	1.5A/1 点 (5A/COM)	6A/1 point	55°C 0.1A/1 点、 50°C 0.15A/1 点、 45°C 0.2A/1 点、 40°C 0.3A/1 点 (2A/COM)	55°C 0.3A/1 点 (2A/COM)
电压规格	250VAC, 30VDC 以下	250VAC, 30VDC 以下	30VDC	30VDC
最大负载	*2	*3	9W	9W
反应时间	约 10ms	约 10ms	Off → On 15us On → Off 25us	Off → On 15us On → Off 25us

*1: 仅适用于 06SN11R 机种

*2: 请参考英文版[Figure 1]

*3: 请参考英文版[Figure 2]

安装及配线

数字 I/O 扩展机的端子配置图

请参考英文版之端子配置图。

系统组合

步骤 1 利用螺丝起子将扩展侧盖打开，会出现扩展机连接接口。（请参考英文版[Figure 3]）



步骤 2 再利用螺丝起子将扩展机固定扣往上拨。（请参考英文版[Figure 4]）

步骤 3 调整好主机和扩展机的定位孔，并且将主机的扩展机接口与扩充机接合，此时主机与扩展机之间紧密结合。（请参考英文版[Figure 5]）

步骤 4 将扩展机固定扣往下扣住，完成与主机之系统组合。（请参考英文版[Figure 6]）

盘内安装及配线

DVP 系列 PLC 在安装时，请装配于封闭式之控制箱内，其周围应保持一定的空间（如下图所示），以确保 PLC 正常散热。



注意事项

- 请勿将 PLC 装置于
- 落尘大、油烟、金属性粉尘及腐蚀性或可燃性气体的环境
 - 高温、结露的环境
 - 有直接振动及冲击的场所

施工注意

- 锁螺丝及配线时请避免微小的金属导体掉入 PLC 内部。
- PLC 与其它之控制元件应保持 50mm 以上的间隔，并应远离高压线及动力设备。

输出点序号排列

无论使用任何点数的主机连接扩展机，所连接的第一台扩展机，输入点编号由 X20 依序排列，输出点编号亦由 Y20 开始依序排列，主机连接数字扩展机最多可连接 14 台，若使用者所连接的系统如下：

系统组合范例：

PLC	机种	输入点数	输出点数	输入点编号	输出点编号
MPU	SS/SA/SX/SC	8	4/6	X0～X7, X10, X11	Y0～Y5, X10, X11
EXT1	16SP11T	8	8	X20～X27	Y20～Y27
EXT2	08SM11N	8	0	X30～X37	-
EXT3	06SN11R	0	6	-	Y30～Y35
EXT4	08SP11R	4	4	X40～X43	Y40～Y43

第 3 台扩展机 06SN11R 会被视为 8 点输出，序号较高的 2 个输出点则没有对应实际的输出点。

第 4 台扩展机 08SP11R 会被视为 8